

**ORDINANCE NO. 1141**

**AN ORDINANCE AMENDING SECTION 15-419 OF THE HORTON MUNICIPAL CODE REGARDING SEWER SPECIFICATIONS FOR THE CITY OF HORTON, KANSAS.**

BE IT ORDAINED by the governing body of the City of Horton, Kansas:

Section 1. Section 15,419 of the Horton Municipal Code is hereby amended as follows:

“15-419. SEWER SPECIFICATIONS. The size, slope, alignment, materials of construction of a building sewer, and the methods to be used in excavating and backfilling the trench, installing jointing, and testing the building sewer, shall conform to the Uniform Plumbing Code as hereinafter modified.

- (a) Minimum internal pipeline diameter for all building sewers shall be four inches (10.2 CM).
- (b) Building sewers shall be constructed of one of the following pipeline materials:
  - (1) Extra-strength vitrified clay pipeline and fittings conforming to ASTM C 700.
  - (2) Polyvinyl chloride (PVC) gravity sewer pipe and fittings, Type PSP or PSM conforming to ASTM Standards D 3033 or D 3034. All PVC sewer pipe shall be Schedule 40 or SDR 21 Series gasketed pipe.
  - (3) ABS composite sewer pipe conforming to ASTM D 2680.
  - (4) Reinforced plastic mortar pipe conforming to ASTM D 3262.
  - (5) Cast or ductile iron pipe with a minimum pressure rating of 150 pounds per square inch conforming to Federal Specification WW-P421b, or ANSI A21.51, A21.6 or A21.8, except that iron used in the manufacture of pipe shall have minimum design strength value, in pounds per square inch, of 21,000 for bursting strength and 45,000 for modulus of rupture.”

Section 2. This ordinance shall take effect and be in force from and after its passage, approval, and publication in the official city newspaper.

PASSED by the governing body of the City of Horton, Kansas, this 2<sup>nd</sup> day of February, 2015

---

Mayor

ATTEST:

---

City Clerk